

**FIRE INSPECTOR'S
INTER-OFFICE CORRESPONDENCE**

TO: Genaro Argenio, Planning Board Chairman

FROM: Francis Bedetti, Asst. Fire Inspector

SUBJECT: PB-08-20
Walgreens
SBL: 69-2-12.1-8-9-7

DATE: December 10, 2008

Fire Prevention Reference Number: FPS-08-054

A review of the above referenced site plan has been conducted and is disapproved for the following reasons:

- 1) Fire Lane to be 30' including all curb cuts.
Town Code 280-15(B)
- 2) Two separate water supply lines needed from the property line, 1-Domestic, 1-Fire